#### **NET POWER**

TRULY CLEAN, CHEAPER ENERGY





#### **NET Power 50 MW Reference Plant**

- NET Power was invented by 8 Rivers team in 2010.
- Zero emissions power from natural gas at lower cost than a combined cycle plant.
  - 100% Carbon Capture and no NOX, SOX, or particulates.
- NET Power has raised >US\$160M from McDermott, Exelon, and Occidental Petroleum.
- Combustor demonstrated in Q2 2018, multiple commercial projects in development.

#### THE NET POWER **TEAM**

NET POWER IS SUPPORTED BY STRONG PARTNERS WITH DEMONSTRATED EXPERTISE TO DRIVE COMMERCIALIZATION

**NET POWER IS A JOINT VENTURE** THAT LICENSES THE TECHNOLOGY



- Engineering/sales/marketing



- Key OEM partner (2011)
- Turbine design, testing and supply



- Investor (2012)
- EPC and sales expertise




- Investor (2014)
- Operations and owner input



- Investor (2018)
- CO<sub>2</sub> and commissioning expertise



#### THE ALLAM CYCLE RUNS ON SUPERCRITICAL CO2



©8 Rivers Capital, LLC Not to be used without permission.



# NET POWER PLANTS ARE EXTREMELY COMPETITIVE

45Q AND INDUSTRIAL GAS SALES PROVIDE NET POWER WITH A COST ADVANTAGE TODAY.

AT MATURE COSTS, NET POWER PLANTS ARE ABLE TO COMPETE ON ELECTRICITY ALONE.

300 MW<sub>F</sub> COMMERCIAL SCALE

#### Levelized Cost Comparison \$125 Ar sales (\$300/t--\$50/t after SN30) $\blacksquare$ N<sub>2</sub> sales (\$8/t--\$2/t after SN30) ■ CO<sub>2</sub> sales (\$15/t EOR & \$35/mt 45Q)\* \$100 ■0&M Fuel Cost Capital Cost Recovery \$75 \$64 \$/MWh \$50 \$44 \$35 \$25 \$20 \$0 -\$25 -\$50 **NET Power NET Power** Combined Combined Nth of a kind Cycle Gas Cycle w/ CCS Plant

\*Based on recent 45Q tax incentives in the US for EOR. \$35/metric tonne tax credit for EOR is converted to a pre-tax \$/short ton basis to illustrate equivalent impact (assumes 0.907185 tonne/ton and 21% corporate tax).

Notes: Assumes \$2.85/MMBTU natural gas in 2018, with annual escalation at 2%. All data for utility-scale projects. Capacity payments and other ancillary service revenue not included



#### 50MW<sub>TH</sub> PLANT IN LA PORTE TX

\$160M+ DESIGN, CONSTRUCTION, AND TESTING PROGRAM

#### 2016

CONSTRUCTION START (MAR)

#### 2017

CONSTRUCTION COMPLETE (DEC)

#### 2018

COMMISSIONING COMPLETE (APR)

COMBUSTOR FIRST FIRE (MAY)


COMBUSTOR TEST COMPLETE (AUG)

#### 2019

POWER TO THE GRID (SOON)







La Porte, TX Demonstration Plant



MCDERMOTT 8 R I V E R S



## TEST PLAN AND RESULTS

FULL TESTING BEGAN Q4 2018. TESTING ONGOING.

FULL CONFIGURATION WITH TURBINE IN HOT GAS PATH

#### Successful Combustor Plant Testing

- PLANT RUN THROUGH STARTUP, SHUTDOWN, AND TRANSIENT/EXCURSION TESTING AT KEY OPERATING POINTS
- TURBINE OPERATING AT RATED SPEED, BUT FLOW PATH ISOLATED

#### EARLY RESULTS

- 600 1000h of major equipment runtime
- 170h RUNTIME WITH FUEL/O2 IN THE CYCLE
  - (26.5H SINGLE RUN)
- CYCLE TEMPERATURES OVER 1000°F, 40% OF FULL LOAD FLOWRATE
- CYCLE PERFORMANCE MATCHES MODELED PERFORMANCE

#### EARLY LESSONS

- TUNING OF OXYGEN AND OXIDANT SUPPLY SYSTEM FOUNDATIONAL TO CYCLE STABILITY
- PROCESS REACHES HIGHLY CONTROLLED STEADY STATE AT ELEVATED TEMPERATURE AND PRESSURE



## 1<sup>ST</sup> COMBUSTOR VALIDATION

# COMBUSTOR DEMONSTRATED AT FULL COMMERCIAL SCALE

#### Commercial Scale Combustor Validated

## DEMONSTRATION (50 MWTH)

COMMERCIAL 300 MWE PLANT 12 X (50 MWTH) COMBUSTORS




Image meant to be a visual aid for relative combustor-turbine configuration, not actual NET Power compressor, combustor, or turbine. This image is a Mitsui SGT-750 industrial gas turbine. This image only used in this presentation for this Mitsui meeting. It does not, and will not, appear in any other NET Power material.

Source: http://www.energy.Mitsui.com/br/en/fossil-power-generation/gas-turbines/sgt-750.htm



#### 300 MW<sub>E</sub> COMMERCIAL PROJECTS

MULTIPLE 300 MW SCALE
PROJECTS UNDER CONSIDERATION

COMPLETED DETAILED PRE-FEED FOR A 303 MWE PLANT

SCALING FROM LA PORTE PLANT:

 COMBUSTOR: NO SCALE-UP, TESTING FULL-SCALE

• TURBINE SHELL: 2.5X SCALE-UP

 BALANCE OF PLANT: COMPONENTS COMMERCIALLY AVAILABLE AT SCALE




Plant outputs		
Electric Output	303MW	
CO <sub>2</sub> Output	<ul><li>890,000 ton/year</li><li>40 million scf/day</li></ul>	
N <sub>2</sub> Output	4.2 MM ton/year	
Ar Output	70,000 ton/year	
ASU O <sub>2</sub>	4,200 ton/day	
Site Area	13 acres	

Commercial Plant Performance*				
Thermal Heat Input (MW)	549.1	100%		
Turbine Shaft Power (MW)	453.0	-18%		
Shaft-mounted CO <sub>2</sub> compressor and generator	-47.9	-8%		
Gross Electrical Output (MW)	405.1			
ASU auxiliary load	-65.1	-12%		
BOP parasitics (pumps, cooling tower, etc.)	-37.5	-7%		
Net Electrical Output (MW)	302.5	55.1%		
Net Plant Efficiency (% on LHV)*	55.1%	55.1%		
Net Plant Heat Rate (LHV)*	6,193	6,193		
* Efficiency optimized for US economics. For countries with high gas prices, 58.9% efficiency is achievable at higher capital cost.				




#### 150 MWH OF CHEAP ENERGY STORAGE

Normal Operations



Energy Storage Input (30 MW / 5 HR) O<sub>2</sub> Tank
Air Separation
NET Power
Grid
30 MW


Energy Storage Output (30 MW / 5 HR)





#### 8 RIVERS IS DEVELOPING ALLAM CYCLE COAL

The Allam Cycle can be used with solid fuels while maintaining all the benefits of the core Allam Cycle.



Efficiency	LHV	HHV
Gross Turbine Output	76.3%	72.5%
Coal prep & feed	-0.2%	-0.2%
ASU	-10.2%	-9.7%
CO <sub>2</sub> , Syngas Comp.	-9.1%	-8.7%
Other Auxiliaries	-6.5%	-6.1%
Net Efficiency	50.3%	47.8%

- High efficiency with existing gasifiers.
- Can use unique impurity removal methods.
- Special material considerations to prevent corrosion.
- Zero emissions, including CO<sub>2</sub>, SOx, NOx, Hg, particulates.




#### CO<sub>2</sub> CAN BE SEQUESTERED

ENHANCED OIL RECOVERY (EOR)
USES CO<sub>2</sub> FOR THE PRODUCTION
OF OIL, WHILE BEING NET CARBON
NEUTRAL (~1 CARBON ATOMS
SEQUESTERED FOR EVERY CARBON
ATOM IN OIL)

CO<sub>2</sub> CAN ALSO BE SEQUESTERED IN IN DEEP SALINE FORMATIONS

IN THE US, 45Q PROVIDES FEDERAL TAX CREDIT OF \$50/TONNE FOR SEQUESTRATION AND \$35 FOR EOR







## **NET POWER**

+1 (919) 667-1800

ADAM.GOFF@8RIVERS.COM

<u>www.NETPower.com</u> / <u>www.8Rivers.com</u>




#### ALLAM CYCLE NATURAL GAS PLATFORM

OXY-FUEL, SEMI-CLOSED-LOOP, WITH A CO<sub>2</sub> WORKING FLUID.

55 TO **59% (LHV)** NET **EFFICIENCY** (CAN BE **ADJUSTED**), WITH **CAPTURE** OF >97% OF CO<sub>2</sub>.

CO<sub>2</sub> AND WATER ARE THE ONLY EFFLUENTS. ASU ALSO PRODUCES SALEABLE BYPRODUCTS.

A NEAR-TERM CO<sub>2</sub> SOLUTION THAT UTILIZES MOSTLY EXISTING EQUIPMENT IN A NOVEL WAY.





# THE ALLAM CYCLE IS A DIFFERENT KIND OF BRAYTON CYCLE

TURBINES ARE DRIVE BY "MASS" AND "HEAT"

The Allam Cycle increases mass by replacing the  $\rm N_2$  in the air with a much greater mass of  $\rm CO_2$ 


THE ALLAM CYCLE RECUPERATES EXHAUST HEAT TO WARM THE CO<sub>2</sub> TO HIGH TEMPERATURES

THE SHARPLY INCREASED

EFFICIENCIES ARE USED TO OFFSET

THE PARASITIC LOADS OF AIR

SEPARATION AND RECOMPRESSION






WIDTH OF LINES PROPORTIONAL TO MASS.

#### NET POWER IS ABOUT MORE THAN POWER

VALUE OF INDUSTRIAL GAS STREAM APPROACHES VALUE OF ELECTRICITY

**45Q** TAX CREDITS FOR  $CO_2$  CAPTURE PROVIDE \$35-50/TON FOR NET POWER'S  $CO_2$ .






# 8 RIVERS HYDROGEN CAN INTEGRATE WITH THE ALLAM CYCLE


8 RIVERS HAS INVENTED A
HYDROGEN TECHNOLOGY WITH
90% CARBON CAPTURE
THATOUTCOMPETES STEAM
METHANE REFORMING.

AN OPTIONAL ALLAM CYCLE INTEGRATION GIVES IT 100% CO<sub>2</sub> CAPTURE AND HIGHER EFFICIENCY.






#### 8 Rivers POX-GHR Hydrogen Process



#### Levelized Cost of 8 Rivers Hydrogen





#### THE DEMAND FOR CO<sub>2</sub> IS SUBSTANTIAL


DEMAND FOR CO<sub>2</sub> FROM NET POWER PLANTS OUTSTRIPS IEA PROJECTIONS FOR NEW AND REPLACEMENT POWER PLANTS

#### Power

NUMBER OF NET POWER 300 MW PLANTS NEEDED BY REGION TO FULFILL NEW AND REPLACEMENT FOSSIL BUILDS

#### $\mathsf{CO}_{\mathbf{2}}$

NUMBER OF NET POWER 300 MW
PLANTS NEEDED FOR TO MEET CURRENT
CO<sub>2</sub> DEMAND FOR EOR, ECBMR, AND
CEMENT



- Power Demand to 2040 (IEA) (total units 4,108) (3.5 billion tpy CO₂)
- (4.9 billion tpy CO<sub>2</sub>)
- ■ECBMR Demand (Godec, Dipietro) (total units 21,601) (17.7 billion tpy CO₂)
- Cement (USGS 2012) (total units 1415) (1.2 billion tpy CO₂)



#### THE NET POWER ADVANTAGE -THE ALLAM CYCLE

THIS DIAGRAM HAS "PRESSURE" LOGARITHMICALLY SPACED UP AND DOWN.

AND "ENTHALPY" IS EVENLY SPACED FROM LEFT TO RIGHT. ENTHALPY IS A MEASURE OF ENERGY. AS YOU MOVE FROM LEFT TO RIGHT, YOU ARE INJECTING ENERGY INTO THE SYSTEM, AND VICE VERSA.


TEMPERATURE IS ON THE UP-DOWN BLUE LINES. TO THE RIGHT, THEY AND ENTHALPY MOVE TOGETHER.

The "Dome" is an important landmark. Above the top,  $CO_2$  is "supercritical". Below the top and to the right,  $CO_2$  is a Gas, and to the left,  $CO_2$  is a liquid. Inside, it is a mixture of Gas and Liquid.

One more thing. The purple lines are "entropy" lines. Think of these as railroad tracks for going up and down in pressure. In the turbine, the tracks go from upper right and down and to the left. The left-right distance in enthalpy is the amount of power the turbine produces.

NOTE THAT ON THE LEFT, THESE RAILROAD TRACKS ARE STEEPER, AND THOSE FOR THE PUMP ARE STEEPER THAN THOSE FOR THE COMPRESSOR. THAT MEANS IT TAKES LESS ENERGY (LEFT-RIGHT) TO PUMP THAN TO COMPRESS.

One last thing. The system design point is where the turbine dumps into the heat exchanger. Ask yourself "why?"





#### 45Q TAX CREDIT FOR CO<sub>2</sub> CAPTURE AND STORAGE

ELIGIBLE FACILITIES CAN CLAIM CREDITS FOR UP TO 12 YEARS

JANUARY 1, 2024 DEADLINE TO COMMENCE CONSTRUCTION

IF CO<sub>2</sub> USED FOR EOR, MUST CAPTURE AT LEAST 500,000 TONNES/YEAR.

Credits assigned to the facility operator, may be transferred to the  ${\rm CO}_2$  storage entity

- Ø TAX LEGISLATION (45Q) PASSED IN THE U.S. IN FEB '18, PLACING SIGNIFICANT VALUE ON CAPTURED AND SEQUESTERED CO2
- TAX CREDIT VALUE IS \$428M (PRE-TAX REAL VALUE BASIS) FOR A 2022 COD PROJECT WITH EOR

	EOR or Chemical Conversion	Sequestration
2021 (ramping from present to 2026)	\$24/mt	\$36/mt
2026 (ramped at inflation after 2026)	\$35/mt	\$50/mt





# NET POWER COMPLEMENTS RENEWABLES

DEEP DECARBONIZATION, WITHOUT DIMINISHING RETURNS.

SOLAR AND WIND'S RELIANCE ON NATURAL GAS BACK-UP CEASES TO BE A CO<sub>2</sub> PROBLEM WITH NET POWER

#### Turns out wind and solar have a secret friend: Natural gas



By Chris Mooney

- NET POWER REMOVES SOLAR AND WIND'S RELIANCE ON COMBINED CYCLE
- OUR RAMP RATE IS HIGHER THAN CCGT AND COMPARABLE TO CT
- EACH PLANT CAN CREATE ≥150 MWH OF ELECTRICITY STORAGE

#### NETPOWER'S ECONOMICS ARE DIFFERENT

- MOST CARBON CAPTURE PROJECTS FAIL IN A HIGH RENEWABLES WORLD BECAUSE THEY CAN'T SURVIVE LOW CAPACITY FACTORS.
- NET POWER RETAINS ITS ADVANTAGE OVER CCGT REGARDLESS OF CAPACITY FACTOR, BECAUSE NET POWER'S CAPEX-OPEX RATIO IS EQUIVALENT TO CCGT.



## **NET POWER**

+1 (919) 667-1800

ADAM.GOFF@8RIVERS.COM

<u>www.NETPower.com</u> / <u>www.8Rivers.com</u>

