



CO₂ The capture plant, Scale –Up challenges

Olav Falk-Pedersen

How does CO₂ capture work?



The capture plant



Challenging to catch CO₂ from flue gas





Illustration source: Freund, Kaarstad "Keeping the Lights on", Universitetsforlaget, 2007

Gas turbine exhaust gas (420MW)


Temperature, °C	105	
Pressure, barg	Atmospheric	Large volume flow Large absorber diameter
Mass Flow Rate, kg/sec	694	
Composition (mass% / vol%)		High degradation
Nitrogen	73.6 / 74.8	
Oxygen	14.4 / 12.8	High absorber Special amines High energy consumption
Carbon Dioxide	5.9 / 3.8	
Water	4.9 / 7.7	
Argon	1.2 / 0.9	
NH ₃	5 ppmv	
SO ₂	0.1 ppmv	Low degradation
Total NO _x	2.0 ppmv	



Absorber design:

- Flow area: 240m²
- Height: 50-60m
- Packing:
 - One production line in one year
 - Lay down area 100 x 150 m





Energy Consumption

Reboiler:


- Heat input: 110-130 MW


Electricity consumption:


- In the process: 12-13 MW
- Compression: 15-17 MW
- Power plant efficiency reduced from 59 to 50%

Energy cost:

- Cost of electric (NOK/kWh)
- Cost of steam (NOK/ton)







Cooling water:

- Sea water
- Typically 22000 – 25000 m³/hour
- Location of inlet and outlet (255MW)

Inlet:


Length: app 2 500 m

Diameter: 5,5 – 6,5 m

Outlet:

Length: app 1 000 m

Diameter: 5,5 – 6,5 m



Capacity of the fjord wrt. temperature and eutrofication

Seasonal variations

Interference with other cooling water discharge points

Crossing of interests with anchoring of ships

Disturbance of export gas pipes

Transport of rock material


Activity	Volume (m ³)	Trucks loads
Inlet tunnel	90.000	18.000
Outlet tunnel	32.000	6.400
Site preparation	93.700	18.740
Total to external deposit	215.700	43.140
Backfilling	24.000	4.800
Total	239.700	47.940

Traffic safety

Noise

Dust

Connection to HRSG




Very sensible for changes in operating pressure (typical numbers gas turbine outlet):

- Operating pressure approximately 46-47 mbar (g)
- The maximum pressure fluctuations in normal operation should be +/- 0,2 mbar.
- Increased back pressure at the gas turbine exhaust gas will reduce the gas turbine efficiency. The gas turbine will most likely be shut down at an increase in back pressure of approximately 13-20 mbar.
- The HRSG is not designed for vacuum.


Connection to HRSG

- Two proposed solutions:
 - 100% of the exhaust gas to be routed to the capture plant.
 - Less than 100% of the exhaust gas to be routed to the capture plant. Example:
 - Approximately 94% of the power plant flue gas routed to the CO₂ capture plant.
 - 90% recovery in the CO₂ capture plant
 - The overall CO₂ recovery will meet the 85% overall recovery requirement

**85% reduction in CO2 emissions
Availability and capture rate**



Reduced production of
electricity



Reduction in power production/ton of steam extracted
Electricity price

Construction philosophy

Area	Philosophy
Amine plant	Prefabricate modules Site-build of foundations Slip-form concrete structure
Chilled Ammonia plant	Stick-build at site Site-build of foundations Slip-form concrete structure
Utilities and infrastructure	Prefabricate modules Prefabricate concrete elements

Site



Fabrication of equipment



Installation of equipment



Flue gas ducting



– catching our future

